

Approval Number: 1703547  
Test Report: M106338



26<sup>th</sup> May 2017

Guarniflon SpA  
Via T Tasso 12,  
24060 Tagliuno Di Castelli,  
Calepio (BG),  
Italy

Water Regulations Advisory Scheme Ltd.  
Unit 13,  
Willow Road,  
Pen y Fan Industrial Estate,  
Crumlin,  
Gwent,  
NP11 4EG

**WATER REGULATIONS ADVISORY SCHEME LTD. (WRAS)**  
**MATERIAL APPROVAL**

The material referred to in this letter is suitable for contact with wholesome water for domestic purposes having met the requirements of BS6920-1:2000 and/or 2014 'Suitability of non-metallic products for use in contact with water intended for human consumption with regard to their effect on the quality of the water'.

The reference relates solely to its effect on the quality of the water with which it may come into contact and does not signify the approval of its mechanical or physical properties for any use.

**POLYTETRAFLUOROETHYLENE (PTFE) - MATERIAL ONLY.**

**5295**

'PTFE G405'. White coloured, compression moulded, PTFE material. For use with water up to 85°C.

**APPROVAL NUMBER: 1703547**  
**APPROVAL HOLDER: GUARNIFLON SPA**

The Scheme reserves the right to review approval.  
Approval 1703547 is valid between March 2017 and March 2022

An entry, as above, will accordingly be included in the Water Fittings Directory on-line under the section headed, "Materials which have passed full tests of effect on water quality".

The Directory may be found at: [www.wras.co.uk/directory](http://www.wras.co.uk/directory)

Yours faithfully

A handwritten signature in black ink, appearing to read 'Jason Furnival', written in a cursive style.

Jason Furnival  
Approvals & Enquiries Manager  
Water Regulations Advisory Scheme